

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 2560-1055:101

Page 1 of 1

**CATEGORY:** Plastics

**LISTEE:** King & Co., PO Box 10, Clarksville, AR 72830  
Contact: BJ Stone \*(479) 754-6090 FAX (479) 754-8445

**DESIGN:** Models THERMO-TILE 2200, 5827, 2201, and 4124 plastic ceiling tile; polystyrene, 1.75 lbs./cu. Ft. density for suspended tee bar non-rated ceilings. Refer to listee's data sheet for detailed product description and operational considerations.

<b>RATING:</b>	<b>ITEM</b>	<b>FLAMESPREAD</b>	<b>SMOKE DENSITY</b>
	5/8"	5	42-128
	1"	10	264-407

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and FM label.

**APPROVAL:** Listed as plastic ceiling finish material for suspended, non-rated ceilings where permitted by code. Also suitable for use with automatic fire sprinklers except where prohibited by code.

\*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**